

- a 0.
- b 1.**
- c 2.
- d 3.

28 o/c7 **13A socket-outlets are to be installed in a location containing a bathtub. The minimum distance they may be located from zone 1 is**

- a 1m
- b 2m
- c 3m**
- d 4m.

Answer c See Part 7: Special installations or locations, Regulation 701.512.3.

29 o/c8 app12 - The voltage drop between the origin of an installation and any load point, supplied from a public LV system, should not be greater than:

- a 3% for lighting and 5% for other uses**
- b 6% for lighting and 8% for other uses
- c 4% for lighting and 4% for other uses
- d 5% for lighting and 5% for other uses -

30 oc8 **The ambient air temperature rating factor for 90 °C thermosetting cables operating in an ambient air temperature of 60 °C is**

- a 0.50
- b 0.56
- c 0.63
- d 0.71.**

Table 4B1 app4